

Quality Requirements for High-voltage Three-phase Cage Induction Motors (IEC)

Revision history

VERSION	DATE	PURPOSE
2.0	November 2024	Second Edition
1.0	January 2021	First Edition

Acknowledgements

This IOGP Specification was prepared by a Joint Industry Programme 33 Standardization of Equipment Specifications for Procurement organized by IOGP with support by the World Economic Forum (WEF).

Disclaimer

Whilst every effort has been made to ensure the accuracy of the information contained in this publication, neither IOGP nor any of its Members past present or future warrants its accuracy or will, regardless of its or their negligence, assume liability for any foreseeable or unforeseeable use made thereof, which liability is hereby excluded. Consequently, such use is at the recipient's own risk on the basis that any use by the recipient constitutes agreement to the terms of this disclaimer. The recipient is obliged to inform any subsequent recipient of such terms.

Please note that this publication is provided for informational purposes and adoption of any of its recommendations is at the discretion of the user. Except as explicitly stated otherwise, this publication must not be considered as a substitute for government policies or decisions or reference to the relevant legislation relating to information contained in it.

Where the publication contains a statement that it is to be used as an industry standard, IOGP and its Members past, present, and future expressly disclaim all liability in respect of all claims, losses or damages arising from the use or application of the information contained in this publication in any industrial application.

Any reference to third party names is for appropriate acknowledgement of their ownership and does not constitute a sponsorship or endorsement.

Copyright notice

The contents of these pages are © International Association of Oil & Gas Producers. Permission is given to reproduce this report in whole or in part provided (i) that the copyright of IOGP and (ii) the sources are acknowledged. All other rights are reserved. Any other use requires the prior written permission of IOGP.

These Terms and Conditions shall be governed by and construed in accordance with the laws of England and Wales. Disputes arising here from shall be exclusively subject to the jurisdiction of the courts of England and Wales.

Foreword

This specification was prepared under Joint Industry Programme 33 (JIP33) "Standardization of Equipment Specifications for Procurement" organized by the International Oil & Gas Producers Association (IOGP) with the support from the World Economic Forum (WEF). Companies from the IOGP membership participated in developing this specification to leverage and improve industry level standardization globally in the oil and gas sector. The work has developed a minimized set of supplementary requirements for procurement, with life cycle cost in mind, resulting in a common and jointly agreed specification, building on recognized industry and international standards.

Recent trends in oil and gas projects have demonstrated substantial budget and schedule overruns. The Oil and Gas Community within the World Economic Forum (WEF) has implemented a Capital Project Complexity (CPC) initiative which seeks to drive a structural reduction in upstream project costs with a focus on industry-wide, non-competitive collaboration and standardization. The CPC vision is to standardize specifications for global procurement for equipment and packages. JIP33 provides the oil and gas sector with the opportunity to move from internally to externally focused standardization initiatives and provide step change benefits in the sector's capital projects performance.

This specification has been developed in consultation with a broad user and supplier base to realize benefits from standardization and achieve significant project and schedule cost reductions.

The JIP33 work groups performed their activities in accordance with IOGP's Competition Law Guidelines (November 2020).

This second edition cancels and replaces the first edition published in January 2021. Due to technical writing requirements leading to extensive changes, this second edition should be treated as a new document.

Table of contents

Foreword.....	1
Introduction	3
1 Scope	4
2 Normative references	4
3 Terms, definitions and abbreviated terms	4
3.1 Terms and definitions	4
3.2 Abbreviated terms	5
4 Quality requirements	6
4.1 Quality management system (QMS).....	6
4.2 Conformity assessment system (CAS)	6
5 Certification and traceability	6
6 Evidence — conformance records	6
Annex A (normative) Purchaser conformity assessment requirements	7
Annex B (normative) Certification and traceability requirements	11

List of tables


Table A.1 — Purchaser conformity assessment requirements	7
Table B.1 — Certification and traceability requirements	11

Introduction

The purpose of this quality requirements specification (QRS) is to specify quality management requirements and the proposed extent of purchaser intervention activities for the procurement of high-voltage three-phase cage induction motors in accordance with IOGP S-704 for application in the petroleum and natural gas industries.

Purchaser intervention activities are identified through the selection of one of four conformity assessment system (CAS) levels based on a risk and criticality assessment. The applicable CAS level is specified by the purchaser in the procurement data sheet (PDS) or purchase order.

The IOGP S-704 specification documents follow a common structure (as shown below) comprising a specification, also known as a technical requirements specification (TRS), a PDS, an information requirements specification (IRS) and this QRS. These four specification documents, together with the purchase order, define the overall technical specification for procurement.



JIP33 Specification for Procurement Documents Quality Requirements Specification (QRS)

This QRS is to be applied in conjunction with the specification, the PDS and the IRS, referred to in this document as IOGP S-704, IOGP S-704D and IOGP S-704L respectively. Further information on the purpose of these documents and the order of precedence for their use is provided in the introduction of the specification.

1 Scope

This QRS specifies quality management requirements for the supply of high-voltage three-phase cage induction motors to IOGP S-704 including:

- a) supplier quality management system (QMS) requirements;
- b) purchaser conformity assessment (surveillance and inspection) activities;
- c) traceability requirements.

2 Normative references

For the purpose of this document, the documents referenced in IOGP S-704 and those listed below, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Specification Q1, *Specification for Quality Management System Requirements for Manufacturing Organizations for the Petroleum and Natural Gas Industry*

EN 10204, *Metallic products - Types of inspection documents*

IOGP S-704, *Supplementary Specification to IEC 60034-1 for High-voltage Three-phase Cage Induction Motors*

ISO 9000:2015, *Quality management systems — Fundamentals and vocabulary*

ISO 9001:2015, *Quality management systems — Requirements*

ISO 10474, *Steel and steel products — Inspection documents*

ISO 29001, *Petroleum, petrochemical and natural gas industries — Sector-specific quality management systems — Requirements for product and service supply organizations*

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

For the purpose of this document, the terms and definitions given in IOGP S-704 and ISO 9000:2015 (normative to ISO 9001:2015) and the following shall apply.

3.1.1

conformity assessment

demonstration that specified requirements are fulfilled

Note 1 to entry: "Conformity assessment" is also referred to as "assessment".

Note 2 to entry: Conformity assessment includes review, inspection, verification and validation activities.

Note 3 to entry: Conformity assessment activities may be undertaken at supplier/sub-supplier premises, virtually by video link, desktop sharing, etc. or by review of information.

3.1.2
conformity assessment system
CAS

system that provides different levels of purchaser interventions to assess and verify supplier conformance to specified requirements

Note 1 to entry: CAS level A applies to the highest risk and associated extent of verification. CAS level D is the lowest.

3.1.3
hold point
H

<conformity assessment> point in the chain of activities beyond which an activity shall not proceed without the approval of the purchaser or purchaser's representative

3.1.4
witness point
W

<conformity assessment> point in the chain of activities at which the supplier shall notify the purchaser or purchaser's representative before proceeding

Note 1 to entry: The operation or process may proceed without witness if the purchaser does not attend after the agreed notice period.

3.1.5
surveillance
S

<conformity assessment> observation, monitoring or review, by the purchaser or purchaser's representative, of an activity, operation, process, product or associated information

3.1.6
review
R

<conformity assessment> review of the supplier's records, procedures and supporting information to verify and/or validate conformance to requirements

3.2 Abbreviated terms

CAS	conformity assessment system
FAT	factory acceptance test
IRS	information requirements specification
ITP	inspection and test plan
PDS	procurement data sheet
QMS	quality management system
QRS	quality requirements specification
TRS	technical requirements specification

4 Quality requirements

4.1 Quality management system (QMS)

The supplier shall operate and maintain a quality management system (QMS) that conforms with ISO 9001, ISO 29001, API Specification Q1 or an equivalent QMS standard.

4.2 Conformity assessment system (CAS)

4.2.1

The CAS provides different levels of assessment of supplier control activities. The CAS level is defined by the purchaser using a risk-based approach and included in the purchase order / contract. The defined CAS level may be adjusted by the purchaser during manufacture based on the supplier's performance and re-assessment of risk.

NOTE For industrial proven solutions, CAS level D is specified unless risk assessment indicates that a more stringent CAS level is required.

4.2.2

Quality plans and inspection and test plans shall include provision for purchaser intervention activities based on the CAS level selected in the PDS or purchase order. See Table A.1.

4.2.3

The supplier's performance in meeting the requirements may be routinely assessed during execution of the scope and, where appropriate, corrective action requested, and conformity assessment activities may be increased or decreased consistent with criticality and risk.

4.2.4

If any subcontracted or scope of supply occurs outside of the primary supplier location, it shall include interventions within the primary inspection and test plan (ITP) or secondary ITP. It is discouraged to use "hold" (H) within Table A.1, section 3 and recommended to use "surveillance" (S).

5 Certification and traceability

The manufacturer shall maintain traceability of sub-assembly components to the original component manufacturer tag / serial number and where applicable, associated certification.

Machine certification and traceability shall be maintained for the components/items listed in Table B.1.

6 Evidence — conformance records

Documents and information shall be provided for in accordance with IOGP S-704L.

Annex A (normative) Purchaser conformity assessment requirements

Table A.1 defines four CAS levels or levels of purchaser assessment.

Table A.1 — Purchaser conformity assessment requirements

Purchaser assessment activities		CAS			
		A	B	C	D
1	Operational planning and control activities				
1.1	Quality planning	H	W	S	-
1.2	Inspection and testing planning	H	W	W	R
1.3	Attend pre-inspection/pre-production (kick-off) meeting for planning of design, review, production and inspection and testing activities	H	H	H	-
2	Design and development activities				
2.1	Attend design review meeting for finalizing design and release for production	H	H	H	-
3	Externally provided products and services (outsourced)				
3.1	Verify external supply scope from sub-suppliers for bought out items List includes sub-suppliers of materials/components such as fixing hardware, bearing assembly, terminal/bushings, heat exchanger (type as applicable), purge unit (for hazardous area installations), control system/panels including wiring and components (IOGP S-704, 11.4.2.3.4, 11.4.3.3.3, 11.4.3.3.5, 11.4.4.2, 11.4.6, 11.4.15.4, Table 26)	H	W	S	-
4	Production and service provision				
4.1	Sub-assembly				
4.1.1	Stator winding inspection prior to impregnation (IOGP S-704, 11.4.4.1, 11.4.4.5, 11.4.4.10)	H	W	S	-
4.1.2	Rotor balancing quality grade check (IOGP S-704, 11.4.5.2, 11.4.5.3, 11.4.5.4, 11.4.5.5, 11.4.5.6, 11.4.5.7)	H	W	W	S
4.2	Inspection and test activities as per IOGP S-704				
4.2.1	In-process testing of motor and associated systems complying to specification, standards, etc. including those in accordance with IOGP S-704, Table 16, section "Special tests", test No.9 "Dielectric dissipation test (tan δ) on stator windings", test No.10 "Partial discharge test on complete stator", test No. 11 "Sealed winding conformance test", test No. 14 "Stator core test" and test No.15 "Surge comparison test of complete stator assembly" (IOGP S-704, 11.4.12.3, Table 16)	H	W	W	-
4.2.2	Final tests, including factory acceptance test (FAT)				
4.2.2.1	Routine test of motor and associated systems in accordance with IOGP S-704, Table 16, section "Routine tests" (IOGP S-704, 8.6.2.3.2, 9.1, 9.2, 10.3, 10.4.2, 10.4.6, 11.1, 11.3.1.1, 11.3.1.5, 11.3.4.3, 11.3.5.1, 11.4.2, 11.4.3.1.2, 11.4.3.2, 11.4.3.3, 11.4.4, 11.4.5, 11.4.6, 11.4.7, 11.4.8, 11.4.9, 11.4.12, 11.4.13, 11.4.15, Table 16, Table 26)	H	W	S	S

Table A.1 (continued)

Purchaser assessment activities		CAS			
		A	B	C	D
4.2.2.2	Special test of motor in accordance with IOGP S-704, Table 16, section "Routine tests", test No. 13 "Measurement of electrical and mechanical run out (measured at slow roll speed - 200 rpm to 300 rpm)" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.3	Performance tests				
4.2.2.3.1	Performance test of motor in accordance with IOGP S-704, Table 16, section "Performance tests", test No. 1 "No-load characteristic (saturation curve) at rated frequency" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.3.2	Performance test of motor in accordance with IOGP S-704, Table 16, section "Performance tests", test No. 2 "Locked rotor current test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.3.3	Performance test of motor in accordance with IOGP S-704, Table 16, section "Performance tests", test No. 3 "Locked rotor torque test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.3.4	Performance test of motor in accordance with IOGP S-704, Table 16, section "Performance tests", test No. 4 "Temperature rise test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.3.5	Performance test of motor in accordance with IOGP S-704, Table 16, section "Performance tests", test No. 5 "Sleeve bearing inspection" (IOGP S-704, Table 16)	H	H	H	H
4.2.2.3.6	Performance test of motor in accordance with IOGP S-704, Table 16, section "Performance tests", test No. 6 "Determination of efficiency, power factor and slip at 100 %, 75 % and 50 % load" for single-speed motor" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.3.7	Performance test of motor in accordance with IOGP S-704, Table 16, section "Performance tests", test No. 6A "Determination of efficiency, power factor and slip at 100 %, 75 % and 50 % load" for converter duty motor" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4	Special tests				
4.2.2.4.1	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 1 "Rated rotor temperature vibration test (heat run test)" (IOGP S-704, Table 16)	H	H	H	H
4.2.2.4.2	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 2 "Overspeed test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.3	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 4 "Measurements of shaft voltage at no-load" (IOGP S-704, Table 16)	H	W	W	S

Table A.1 (continued)

Purchaser assessment activities		CAS			
		A	B	C	D
4.2.2.4.4	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 5 "Bearing temperature rise at no-load" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.5	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 6 "Noise level at no load" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.6	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 7 "Measurement of moment of inertia" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.7	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 8 "Measurement of torque and current as function of speed during starting" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.8	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 9 "Dielectric dissipation test ($\tan \delta$) on stator windings" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.9	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 10 "Partial discharge test on complete stator" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.10	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 11 "Sealed winding conformance test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.11	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 12 "Unbalanced response test" (IOGP S-704, Table 16)	H	H	H	H
4.2.2.4.12	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 13 "Bearing housing natural frequency test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.13	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 14 "Stator core test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.14	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 15 "Surge comparison test of complete stator assembly" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.15	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 16 "Sample coil test" (IOGP S-704, Table 16)	H	W	W	S
4.2.2.4.16	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 17 "Heat exchanger performance verification test" (IOGP S-704, Table 16)	H	W	W	S

Table A.1 (continued)

Purchaser assessment activities		CAS			
		A	B	C	D
4.2.2.4.17	Special test of motor in accordance with IOGP S-704, Table 16, section "Special tests", test No. 18 "Hydrostatic pressure test of heat exchanger tubing devices" (IOGP S-704, Table 16)	H	W	W	S
5	Final inspection				
5.1	Conformance to purchase order				
5.1.1	Verify handling, packaging, preservation and storage of motors before release (IOGP S-704, 6.61, 1.4.7.5)	W	W	S	-
5.1.2	Release equipment for shipment	H	H	H	H
Key - No intervention performed H Hold point W Witness point R Review S Surveillance					

Annex B (normative) Certification and traceability requirements

Table B.1 provides the certification and traceability requirements for the equipment and component parts.

Table B.1 — Certification and traceability requirements

Item		Certificate type ^a	Traceability level ^b	Additional requirements												
Equipment item 1	Heat exchanger assembly	2.1	Level III													
Equipment item 2	Bearing assembly	2.1	Level III													
^a Inspection certificates shall be provided in accordance with ISO 10474 or EN 10204. ^b Traceability levels are defined in the following table. <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Level</th> <th style="width: 20%;">Traceability</th> <th style="width: 70%;">Definition</th> </tr> </thead> <tbody> <tr> <td>Level I</td> <td>Full traceability</td> <td>Material is uniquely identified and its history tracked from manufacture through stockists (where applicable) to the supplier and to the actual position on the equipment with the specific location defined on a material placement record (the traceability to a specific location only applies to skids / packaged equipment, not to bulks).</td> </tr> <tr> <td>Level II</td> <td>Type traceability</td> <td>The supplier maintains a system to identify material throughout manufacture, with traceability to a material certificate.</td> </tr> <tr> <td>Level III</td> <td>Compliance traceability</td> <td>The supplier maintains a system of traceability that enables a declaration of compliance to be issued by the supplier.</td> </tr> </tbody> </table>					Level	Traceability	Definition	Level I	Full traceability	Material is uniquely identified and its history tracked from manufacture through stockists (where applicable) to the supplier and to the actual position on the equipment with the specific location defined on a material placement record (the traceability to a specific location only applies to skids / packaged equipment, not to bulks).	Level II	Type traceability	The supplier maintains a system to identify material throughout manufacture, with traceability to a material certificate.	Level III	Compliance traceability	The supplier maintains a system of traceability that enables a declaration of compliance to be issued by the supplier.
Level	Traceability	Definition														
Level I	Full traceability	Material is uniquely identified and its history tracked from manufacture through stockists (where applicable) to the supplier and to the actual position on the equipment with the specific location defined on a material placement record (the traceability to a specific location only applies to skids / packaged equipment, not to bulks).														
Level II	Type traceability	The supplier maintains a system to identify material throughout manufacture, with traceability to a material certificate.														
Level III	Compliance traceability	The supplier maintains a system of traceability that enables a declaration of compliance to be issued by the supplier.														

Registered Office

City Tower
Level 14
40 Basinghall Street
London EC2V 5DE
United Kingdom
T +44 (0)20 3763 9700
reception@iogp.org

Brussels Office

Avenue de Tervuren 188A
B-1150 Brussels
Belgium
T +32 (0)2 790 7762
reception-europe@iogp.org

Houston Office

15377 Memorial Drive
Suite 250
Houston, TX 77079
USA
T +1 (713) 261 0411
reception-americas@iogp.org

www.iogp.org

