

Date of issue:

June 2025

Affected publication:

IOGP S-720Q, Quality Requirements for Transformers, First Edition, December 2020

ADDENDUM 1

This addendum (Version 1.01) replaces Edition 1.0 published in December 2020.

NOTE: In addition to the updates listed below, minor editorial/typographical amendments may have been made.

List of updates

Section	Update
Annex A table	New row 2.1.2

Quality Requirements for Transformers

Revision history

VERSION	DATE	PURPOSE
1.01	June 2025	Addendum 1
1.0	December 2020	First Edition

Acknowledgements

This IOGP Specification was prepared by a Joint Industry Programme 33 Standardization of Equipment Specifications for Procurement organized by IOGP with support by the World Economic Forum (WEF).

Disclaimer

Whilst every effort has been made to ensure the accuracy of the information contained in this publication, neither IOGP nor any of its Members past present or future warrants its accuracy or will, regardless of its or their negligence, assume liability for any foreseeable or unforeseeable use made thereof, which liability is hereby excluded. Consequently, such use is at the recipient's own risk on the basis that any use by the recipient constitutes agreement to the terms of this disclaimer. The recipient is obliged to inform any subsequent recipient of such terms.

Please note that this publication is provided for informational purposes and adoption of any of its recommendations is at the discretion of the user. Except as explicitly stated otherwise, this publication must not be considered as a substitute for government policies or decisions or reference to the relevant legislation relating to information contained in it.

Where the publication contains a statement that it is to be used as an industry standard, IOGP and its Members past, present, and future expressly disclaim all liability in respect of all claims, losses or damages arising from the use or application of the information contained in this publication in any industrial application.

Any reference to third party names is for appropriate acknowledgement of their ownership and does not constitute a sponsorship or endorsement.

Copyright notice

The contents of these pages are © International Association of Oil & Gas Producers. Permission is given to reproduce this report in whole or in part provided (i) that the copyright of IOGP and (ii) the sources are acknowledged. All other rights are reserved. Any other use requires the prior written permission of IOGP.

These Terms and Conditions shall be governed by and construed in accordance with the laws of England and Wales. Disputes arising here from shall be exclusively subject to the jurisdiction of the courts of England and Wales.

Foreword

This specification was prepared under Joint Industry Programme 33 (JIP33) "Standardization of Equipment Specifications for Procurement" organized by the International Oil & Gas Producers Association (IOGP) with the support from the World Economic Forum (WEF). Companies from the IOGP membership participated in developing this specification to leverage and improve industry level standardization globally in the oil and gas sector. The work has developed a minimized set of supplementary requirements for procurement, with life cycle cost in mind, resulting in a common and jointly agreed specification, building on recognized industry and international standards.

Recent trends in oil and gas projects have demonstrated substantial budget and schedule overruns. The Oil and Gas Community within the World Economic Forum (WEF) has implemented a Capital Project Complexity (CPC) initiative which seeks to drive a structural reduction in upstream project costs with a focus on industry-wide, non-competitive collaboration and standardization. The CPC vision is to standardize specifications for global procurement for equipment and packages. JIP33 provides the oil and gas sector with the opportunity to move from internally to externally focused standardization initiatives and provide step change benefits in the sector's capital projects performance.

This specification has been developed in consultation with a broad user and supplier base to realize benefits from standardization and achieve significant project and schedule cost reductions.

The JIP33 work groups performed their activities in accordance with IOGP's Competition Law Guidelines (November 2020).

Table of Contents

Foreword.....	1
Introduction	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
3.1 Conformity assessment.....	4
3.2 Conformity assessment system (CAS)	4
3.3 Conformity assessment - Hold point (H)	5
3.4 Conformity assessment - Witness point (W)	5
3.5 Conformity assessment - Surveillance (S)	5
3.6 Conformity assessment - Review (R)	5
4 Symbols and abbreviations	5
5 Quality requirements	5
5.1 Quality management system.....	5
5.2 Conformance assessment	5
6 Certification and traceability	6
7 Control of nonconforming products and services.....	6
8 Evidence (conformance records)	6
Annex A (normative) Purchaser conformity assessment requirements	7
Annex B (normative) Certification traceability and requirements	9

Introduction

The purpose of this quality requirements specification (QRS) is to define quality management requirements for the procurement of transformers in accordance with IOGP S-720 for application in the petroleum and natural gas industries.

The QRS includes definition of a conformity assessment system (CAS) which specifies standardized customer interventions against quality management activities at four different levels. The applicable CAS level is specified by the customer in the equipment data sheet or purchase order.

This QRS shall be used in conjunction with the supplementary requirements specification IOGP S-720, the information requirements specification IOGP S-720L and the equipment data sheet IOGP S-720D which together comprise the full set of specification documents. The introduction section in the supplementary requirements specification provides further information on the purpose of each of these documents and the order of precedence for their use.



**JIP33 Specification for Procurement Documents
Quality Requirements Specification**

1 Scope

To specify quality management requirements for the supply of transformers to IOGP S-720 Supplementary Specification to IEC 60076-1 Transformers including:

- a) supplier quality management system requirements;
- b) customer conformity assessment (surveillance and inspection) activities;
- c) traceability requirements;
- d) evidence of conformance;
- e) factory acceptance.

2 Normative references

For the purpose of this document, the documents referenced in S-720 and those listed below, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Specification Q1, *Specification for Quality Management System Requirements for Manufacturing Organizations for the Petroleum and Natural Gas Industry*

IOGP S-720, *Supplementary Specification to IEC 60076-1 Transformers*

ISO 9001, *Quality management systems — Requirements*

ISO 29001, *Petroleum, petrochemical and natural gas industries — Sector-specific quality management systems — Requirements for product and service supply organizations*

3 Terms and definitions

For the purpose of this document, the terms and definitions given in IOGP S-720 and ISO 9000 (normative to ISO 9001) and the following shall apply.

3.1 Conformity assessment

Demonstration that requirements relating to a product, process, system, person or body are fulfilled.

NOTE 1 Conformity assessment (or assessment) includes but is not limited to review, inspection, verification and validation activities.

NOTE 2 Assessment activities may be undertaken at a supplier/sub-supplier's premises, virtually by video link, desktop sharing, etc. or by review of information formally submitted for acceptance or for information.

3.2 Conformity assessment system (CAS)

Systems providing different levels of assessment of the supplier's control activities by the customer (second party) or independent body (third party) based on evaluation of the supplier's capability to conform to the product or service specification and obligatory requirements.

NOTE CAS A reflects the highest risk and associated extent of verification. CAS D is the lowest.

3.3 Conformity assessment - Hold point (H)

Point in the chain of activities beyond which an activity shall not proceed without the approval of the customer or customer's representative.

3.4 Conformity assessment - Witness point (W)

Point in the chain of activities that the supplier shall notify the customer or customer's representative before proceeding. The operation or process may proceed without witness if the customer does not attend after the agreed notice period.

3.5 Conformity assessment - Surveillance (S)

Observation, monitoring or review by the customer or customer's representative of an activity, operation, process, product or associated information.

3.6 Conformity assessment - Review (R)

Review of the supplier's information to verify conformance to requirements.

NOTE Information review requirements are managed on a surveillance basis and as such do not impose schedule constraints, unless specified as hold points in Annex A or as conditions specified in the associated IRS.

4 Symbols and abbreviations

For purposes of this document, the following symbols and abbreviations apply.

CAS	conformity assessment system
IRS	information requirements specification
QRS	quality requirements specification (this document)

5 Quality requirements

5.1 Quality management system

The supplier shall demonstrate that the quality management arrangements established for the supply of products and services conform to ISO 9001, ISO 29001, API Specification Q1 or an equivalent quality management system standard.

5.2 Conformance assessment

5.2.1

Quality plans and inspection and test plans developed as outputs to operational planning and control shall define the specific controls to be implemented by the supplier to ensure conformance with the specified requirements.

5.2.2

Controls shall address both internally and externally sourced processes products and services.

5.2.3

Quality plans and inspection and test plans shall include provision for the customer conformity assessment system (CAS) as specified in the data sheet IOGP S-720D. See Annex A.

5.2.4

Supplier performance in meeting the requirements will be routinely assessed during execution of the scope and where appropriate, corrective action requested and conformity assessment activities increased or decreased consistent with criticality and risk.

NOTE 1 For industrial proven solutions CAS level D is specified unless risk assessment indicates that a more stringent CAS level is required.

NOTE 2 Irrespective of conformity assessment requirements defined by the customer, either, by reference to standard or specification requirements or in the scope, the supplier remains responsible for operational planning and control and demonstration of the conformity of products and services with the requirements. See ISO 9001, 8.1 and 8.2.

6 Certification and traceability

Material certification and traceability shall be maintained in accordance with Annex B.

7 Control of nonconforming products and services

Nonconformance with specified requirements identified by or to the supplier shall be corrected such that the specified requirements are satisfied or the customer's acceptance of the nonconformance agreed in accordance with purchase order conditions. See ISO 9001, 8.2.3, 8.2.4, 8.5.6 and 8.7.

8 Evidence (conformance records)

Plans, procedures, methods and resultant records shall be provided in accordance with the associated IRS.

Annex A

(normative)

Purchaser conformity assessment requirements

This annex defines four conformity assessment systems (CAS) or levels of purchaser assessment.

	PURCHASER ASSESSMENT ACTIVITIES	CAS			
		A	B	C	D
1	Operational planning and control activities				
1.1	Quality planning as per ISO 9001, 8.1 and ISO 10005 (IOGP S-720, 11.1.1)	H	R	-	-
1.2	Inspection and test planning as per ISO 9001, 8.1 and ISO 10005 (IOGP S-720, 11.1.1)	H	R	R	R
1.3	Pre-Inspection/Pre-production planning (IOGP S-720, 11.1.4)	H	-	-	-
2	Design and development activities				
2.1	Design and development planning				
2.1.1	Alignment of general arrangement diagram for the transformer (IOGP S-720, A.1.1 a) to x))	H	H	H	H
2.1.2	Attend design review meeting for finalizing design and release for production	H	H	H	-
2.2	Manufacturing process				
2.2.1	Verification of iron core assembly for the transformer (IOGP S-720, 11.1.4)	W	W	S	-
2.2.2	Verification of winding assembly for the transformer (IOGP S-720, 11.1.4)	W	W	S	-
3	Control of external supply				
3.1	Verification and review of external supplied items such as steel for core and tank, winding conductors and insulation, radiators, tap changers, accessories, insulating liquid, etc. (IOGP S-720, 11.1.1)	W	S	-	-
4	Production and service provision				
4.1	Sub-assembly				
4.1.1	Core and winding pre tanking inspection (IOGP S-720, 11.1.4)	W	S	-	-
4.2	Inspection and testing				
4.2.1	Routine testing (IOGP S-720, 5.7, 5.8, 7.1.5, 8.1, 8.2, 8.3, 9.1, 9.2, 9.6, 11.1, 11.2.1, 11.2.2, 11.2.3, 11.3, 11.4, 11.5, 11.7, 11.8)	W	W	W	R
4.2.2	Performance of type tests, in absence of certificate (IOGP S-720, 11.1, 6.6)	W	W	W	W
4.2.3	Performance of special tests, if specified (IOGP S-720, 11.1.4, 11.1.1, 11.10, 11.11, 11.6, 11.9)	W	W	W	W

	PURCHASER ASSESSMENT ACTIVITIES	CAS			
		A	B	C	D
5	Release of product or service				
5.1	Verify conformance to purchase order				
5.1.1	Witness the handling, preservation and packaging of the transformer before release (IOGP S-720, 9.3)	W	W	S	-
5.1.2	Verify the final documentation as per IOGP S-720L	H	H	W	S
5.1.3	Final inspection and equipment release (IOGP S-720, 11.1.1)	H	H	-	-
H is hold point, W is witness point, S is surveillance and R is review. Note: Definitions for these terms are provided in Section 3 of this document.					

Annex B

(normative)

Certification traceability and requirements

Item		Certificate Type	Traceability level	Additional Requirements
Transformer	Core and windings	3.1	Level II	
	Remaining materials	2.2	Level III	
Explanatory notes Inspection certificates shall be provided in accordance with ISO 10474 or EN 10204. Traceability A. Level I - Full Traceability - Material is uniquely identified and its history tracked from manufacture through stockists (where applicable) to the supplier and to actual position on the equipment with specific location defined on a material placement record (the traceability to a specific location only applies to skids / packaged equipment, not to bulks). B. Level II - Type Traceability - The supplier maintains a system to identify material throughout manufacture, with traceability to a material certificate. C. Level III - Compliance Traceability - The supplier maintains a system of traceability that enables a declaration of compliance to be issued by the supplier.				



IOGP Headquarters

City Tower, 40 Basinghall Street, London EC2V 5DE, United Kingdom
T: +44 20 4570 6879
E: reception@iogp.org

IOGP Europe

T: +32 2 882 16 53
E: reception-europe@iogp.org

www.iogp.org