

Date of issue:

November 2025

Affected publication:

IOP S-740Q, Quality Requirements for Batteries (IEC), First Edition, December 2020

ADDENDUM 1

This addendum (Version 1.01) replaces Edition 1.0 published in December 2020.

NOTE: In addition to the updates listed below, minor editorial/typographical amendments may have been made.

List of updates

Clause/subclause	Update
Annex A table	Row 2.4 list of references updates Row 4.2 list of references updates

Quality Requirements for Batteries (IEC)

Revision history

VERSION	DATE	PURPOSE
1.01	November 2025	Addendum 1
1.0	December 2020	First Edition

Acknowledgements

This IOGP Specification was prepared by a Joint Industry Programme 33 Standardization of Equipment Specifications for Procurement organized by IOGP with support by the World Economic Forum (WEF).

Disclaimer

Whilst every effort has been made to ensure the accuracy of the information contained in this publication, neither IOGP nor any of its Members past present or future warrants its accuracy or will, regardless of its or their negligence, assume liability for any foreseeable or unforeseeable use made thereof, which liability is hereby excluded. Consequently, such use is at the recipient's own risk on the basis that any use by the recipient constitutes agreement to the terms of this disclaimer. The recipient is obliged to inform any subsequent recipient of such terms.

Please note that this publication is provided for informational purposes and adoption of any of its recommendations is at the discretion of the user. Except as explicitly stated otherwise, this publication must not be considered as a substitute for government policies or decisions or reference to the relevant legislation relating to information contained in it.

Where the publication contains a statement that it is to be used as an industry standard, IOGP and its Members past, present, and future expressly disclaim all liability in respect of all claims, losses or damages arising from the use or application of the information contained in this publication in any industrial application.

Any reference to third party names is for appropriate acknowledgement of their ownership and does not constitute a sponsorship or endorsement.

Copyright notice

The contents of these pages are © International Association of Oil & Gas Producers. Permission is given to reproduce this report in whole or in part provided (i) that the copyright of IOGP and (ii) the sources are acknowledged. All other rights are reserved. Any other use requires the prior written permission of IOGP.

These Terms and Conditions shall be governed by and construed in accordance with the laws of England and Wales. Disputes arising here from shall be exclusively subject to the jurisdiction of the courts of England and Wales.

Foreword

This specification was prepared under Joint Industry Programme 33 (JIP33) "Standardization of Equipment Specifications for Procurement" organized by the International Oil & Gas Producers Association (IOGP) with the support from the World Economic Forum (WEF). Companies from the IOGP membership participated in developing this specification to leverage and improve industry level standardization globally in the oil and gas sector. The work has developed a minimized set of supplementary requirements for procurement, with life cycle cost in mind, resulting in a common and jointly agreed specification, building on recognized industry and international standards.

Recent trends in oil and gas projects have demonstrated substantial budget and schedule overruns. The Oil and Gas Community within the World Economic Forum (WEF) has implemented a Capital Project Complexity (CPC) initiative which seeks to drive a structural reduction in upstream project costs with a focus on industry-wide, non-competitive collaboration and standardization. The CPC vision is to standardize specifications for global procurement for equipment and packages. JIP33 provides the oil and gas sector with the opportunity to move from internally to externally focused standardization initiatives and provide step change benefits in the sector's capital projects performance.

This specification has been developed in consultation with a broad user and supplier base to realize benefits from standardization and achieve significant project and schedule cost reductions.

The JIP33 work groups performed their activities in accordance with IOGP's Competition Law Guidelines (November 2020).

Table of contents

Foreword.....	1
Introduction	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
3.1 Conformity assessment.....	4
3.2 Conformity assessment system (CAS)	4
3.3 Conformity assessment - Hold point (H)	5
3.4 Conformity assessment - Witness point (W).....	5
3.5 Conformity assessment - Surveillance (S).....	5
3.6 Conformity assessment - Review (R)	5
4 Symbols and abbreviations	5
5 Quality requirements	5
5.1 Quality management system.....	5
5.2 Conformance assessment	5
6 Certification and traceability	6
7 Control of nonconforming products and services.....	6
8 Evidence (records)	6
Annex A (normative) Purchaser conformity assessment requirements	7

Introduction

The purpose of this quality requirements specification (QRS) is to define quality management requirements for the procurement of batteries in accordance with IOGP S-740 for application in the petroleum and natural gas industries.

The QRS includes definition of a conformity assessment system (CAS) which specifies standardized purchaser interventions against quality management activities at four different levels. The applicable CAS level is specified by the purchaser in the equipment data sheet or purchase order.

This QRS shall be used in conjunction with the specification IOGP S-740, the information requirements specification IOGP S-740L and the equipment data sheet IOGP S-740D which together comprise the full set of specification documents. The introduction section in the specification provides further information on the purpose of each of these documents and the order of precedence for their use.



JIP33 Specification for Procurement Documents Quality Requirements Specification

1 Scope

To specify quality management requirements for the supply of batteries to IOGP S-740 Specification for Batteries (IEC) including:

- a) supplier quality management system requirements;
- b) purchaser conformity assessment (surveillance and inspection) activities;
- c) traceability requirements;
- d) evidence of conformance;
- e) factory acceptance.

2 Normative references

For the purpose of this document, the documents referenced in IOGP S-740 and those listed below, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Specification Q1, *Specification for Quality Management System Requirements for Manufacturing Organizations for the Petroleum and Natural Gas Industry*

IOGP S-740, *Specification for Batteries (IEC)*

ISO 9001, *Quality management systems — Requirements*

ISO 29001, *Petroleum, petrochemical and natural gas industries — Sector-specific quality management systems — Requirements for product and service supply organizations*

3 Terms and definitions

For the purpose of this document, the terms and definitions given in IOGP S-740 and ISO 9000 (normative to ISO 9001) and the following shall apply.

3.1 Conformity assessment

Demonstration that requirements relating to a product, process, system, person or body are fulfilled.

NOTE 1 Conformity assessment (or assessment) includes but is not limited to review, inspection, verification and validation activities.

NOTE 2 Assessment activities may be undertaken at a supplier/sub-supplier's premises, virtually by video link, desktop sharing, etc. or by review of information formally submitted for acceptance or for information.

3.2 Conformity assessment system (CAS)

Systems providing different levels of assessment of the supplier's control activities by the purchaser (second party) or independent body (third party) based on evaluation of the supplier's capability to conform to the product or service specification and obligatory requirements.

NOTE CAS A reflects the highest risk and associated extent of verification. CAS D is the lowest.

3.3 Conformity assessment - Hold point (H)

Point in the chain of activities beyond which an activity shall not proceed without the approval of the purchaser or purchaser's representative.

3.4 Conformity assessment - Witness point (W)

Point in the chain of activities that the supplier shall notify the purchaser or purchaser's representative before proceeding. The operation or process may proceed without witness if the purchaser does not attend after the agreed notice period.

3.5 Conformity assessment - Surveillance (S)

Observation, monitoring or review by the purchaser or purchaser's representative of an activity, operation, process, product or associated information.

3.6 Conformity assessment - Review (R)

Review of the supplier's information to verify conformance to requirements.

NOTE Information review requirements are managed on a surveillance basis and as such do not impose schedule constraints, unless specified as hold points in Annex A or as conditions specified in the associated IRS.

4 Symbols and abbreviations

For purposes of this document, the following symbols and abbreviations apply:

CAS	conformity assessment system
IRS	information requirements specification
QRS	quality requirements specification (this document)

5 Quality requirements

5.1 Quality management system

The supplier shall demonstrate that the quality management arrangements established for the supply of products and services conform to ISO 9001, ISO 29001, API Specification Q1 or an equivalent quality management system standard.

5.2 Conformance assessment

5.2.1

Quality plans and inspection and test plans developed as outputs to operational planning and control shall define the specific controls to be implemented by the supplier to ensure conformance with the specified requirements.

5.2.2

Controls shall address both internally and externally sourced processes products and services.

5.2.3

Quality plans and inspection and test plans shall include provision for the purchaser conformity assessment system (CAS) as specified in the data sheet. See Annex A.

5.2.4

Supplier performance in meeting the requirements will be routinely assessed during execution of the scope and where appropriate, corrective action requested and conformity assessment activities increased or decreased consistent with criticality and risk.

NOTE 1 For industrial proven solutions CAS level D is specified unless risk assessment indicates that a more stringent CAS level is required.

NOTE 2 Irrespective of conformity assessment requirements defined by the purchaser, either, by reference to standard or specification requirements or in the scope, the supplier remains responsible for operational planning and control and demonstration of the conformity of products and services with the requirements. See ISO 9001, 8.1 and 8.2.

6 Certification and traceability

The manufacturer/supplier shall maintain traceability of bulk materials, parts and components to the original material/component manufacturer/supplier lot/batch number and where applicable, associated certification. See ISO 9001, 8.5.2.

7 Control of nonconforming products and services

Nonconformance with specified requirements identified by or to the supplier shall be corrected such that the specified requirements are satisfied or the purchaser's acceptance of the nonconformance agreed in accordance with purchase order conditions. See ISO 9001, 8.2.3, 8.2.4, 8.5.6 and 8.7.

8 Evidence (records)

Plans, procedures, methods and resultant records shall be provided in accordance with the associated IRS.

Annex A (normative)

Purchaser conformity assessment requirements

This annex defines four conformity assessment systems (CAS) or levels of purchaser assessment.

	PURCHASER ASSESSMENT ACTIVITIES	CAS			
		A	B	C	D
1	Operational planning and control activities				
1.1	Quality planning (ISO 9001, 8.1 and ISO 10005)	H	W	-	-
1.2	Inspection and test planning (ISO 9001, 8.1 and ISO 10005)	H	H	R	R
1.3	Pre-Inspection/Pre-production planning	H	H	W	S
2	Design and development activities				
2.1	Calculations (battery sizing and back up time) (IOGP S-740, 5.1, Clause 7)	H	H	R	R
2.2	Verification of the design performance characteristics (data sheet) (IOGP S-740, 5.4, 5.6, 6.2)	H	H	R	R
2.3	Verification of equipment layout design (general arrangement drawings) (IOGP S-740, 10.1.1, 10.1.2, 10.1.3, 10.1.4, 10.1.5, 10.1.6, 10.1.7, 10.2.1, 10.2.10, 10.2.2, 10.2.3, 10.2.4, 10.2.5, 10.2.6, 10.2.7, 10.2.8, 10.2.9)	H	H	R	R
2.4	Verification of component selection (bill of materials) (IOGP S-740, 9.1.1, 9.1.2, 9.1.5, 9.2.1, 9.2.2, 9.2.3, 9.2.4)	H	H	R	R
2.5	Review of certificates (including type test certification) (IOGP S-740, 10.2.1, 10.3, 10.4, 4.1, 5.7, 6.1.1, 6.1.3)	H	H	R	R
3	Control of external supply				
3.1	External supply scope, risk assessment and controls (ISO 9001, 8.4)	H	W	-	-
3.2	Nominated sub-suppliers of sub-assemblies, components and accessories	H	W	-	-
4	Production and service provision				
4.1	Verification of incoming materials (type, condition/integrity, environmental compliance, quantity and certification) (IOGP S-740, 10.2.1, 10.5.1, 10.5.2, 4.2)	H	S	-	-
4.2	Verification of assembly (including review of in process records) (IOGP S-740, 10.2.1, 6.1.2, 6.1.4, 6.1.5, 6.2, 9.1.4)	W	-	-	-
4.3	Battery testing in accordance with IEC standards specified in IOGP S-740, Table 3, and verification of test reports (IOGP S-740, 10.2.2, 10.3, 10.4, Clause 8, Table 3)	H	W	R	R
5	Release of product or service				
5.1	Handling, packing, preservation and storage (IOGP S-740, 11.1, 11.2)	W	W	S	-
5.2	Final documentation review	H	H	H	H
5.3	Release equipment	H	H	H	H

	PURCHASER ASSESSMENT ACTIVITIES	CAS			
		A	B	C	D
6	Integration testing				
6.1	Site test as part of commissioning test (IOGP S-740, Clause 8)	W	W	W	W
H is hold point, W is witness point, S is surveillance and R is review. NOTE Definitions for these terms are provided in Clause 3.					



IOGP Headquarters

Level 6, 3 Moorgate Place, London, EC2R 6EA, United Kingdom
T: +44 20 4570 6879
E: reception@iogp.org

IOGP Europe

T: +32 2 882 16 53
E: reception-europe@iogp.org

www.iogp.org